



Product Service

# Attestation of Conformity

No. N8A 086688 0364 Rev. 01

**Holder of Attestation:** **Qingdao Hisense Hitachi Air-conditioning Systems Co., Ltd**

No.218, Qianwangang Road  
Economic and Technological Development Zone  
266555 Qingdao  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Heat pumps  
(Heat pump)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64111230218402

**Date,** 2023-11-17

( Gary Sun )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

# Attestation of Conformity

No. N8A 086688 0364 Rev. 01

**Model(s):** Indoor unit/outdoor unit  
**AHS-100HCDSAA-23/AHW-100HCDS1,**  
**AHS-120HCDSAA-23/AHW-120HCDS1,**  
**AHS-140HCDSAA-23/AHW-140HCDS1,**  
**AHS-160HCDSAA-23/AHW-160HCDS1**

**Brand:** Hisense

**Parameters:** Rated Voltage: 220-240V~  
 Rated Frequency: 50Hz  
 Refrigerant: R32  
 Protection Class: Class I  
 Degree of Protection: IP X4 for outdoor unit,  
 IP X1 for indoor unit

Model	Rated power input	Rated current
AHW-100HCDS1	4,48kW	/
AHW-120HCDS1	5,55kW	
AHW-140HCDS1	6,61kW	
AHW-160HCDS1	8,20kW	
AHS-100HCDSAA-23	1,9kW for main supply 6,0kW for auxiliary electric heater supply	8,75A for main supply 28,7A for auxiliary electric heater supply
AHS-120HCDSAA-23		
AHS-140HCDSAA-23		
AHS-160HCDSAA-23		

**Tested according to:** EN 60335-1:2012/A15:2021  
 EN 60335-2-40:2003/A13:2012  
 EN 60335-2-21:2021/A1:2021  
 EN 62233:2008

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

