



Product Service

Attestation of Conformity

No. N8A 086688 0314 Rev. 00

Holder of Certificate: **Qingdao Hisense Hitachi Air-conditioning Systems Co., Ltd**
No.218, Qianwangang Road
Economic and Technological Development Zone
266555 Qingdao
PEOPLE'S REPUBLIC OF CHINA

Product: **Heat pumps
(Heat pump)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64111220346801

Date, 2022-11-23

(Gary Sun)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 086688 0314 Rev. 00

Model(s): indoor unit / outdoor unit
AHS-044HCDSAA-23/AHW-044HCDS1,
AHS-060HCDSAA-23/AHW-060HCDS1,
AHS-080HCDSAA-23/AHW-080HCDS1

Brand: Hisense

Parameters:

Rated Voltage:	220-240V~
Rated Frequency:	50Hz
Rated Power/Current:	Cooling/ Heating
AHS-044HCDSAA-23	6,8kW/29,56A
AHS-060HCDSAA-23	6,8kW/29,56A
AHS-080HCDSAA-23	6,8kW/29,56A
AHW-044HCDS1	2,23kW/9,80A
AHW-060HCDS1	2,73kW/12,00A
AHW-080HCDS1	3,75kW/16,80A
Protection Class	Class I
Degree of Protection:	IPX4 for outdoor unit, IPX1 for indoor unit
Refrigerant:	R32

Tested according to:
 EN 60335-1:2012/A15:2021
 EN 60335-2-40:2003/A13:2012
 EN 62233:2008
 EN 60335-2-21:2021/A1:2021