



Product Service

Attestation of Conformity

No. E8A 086688 0317 Rev. 00

Holder of Certificate: **Qingdao Hisense Hitachi Air-conditioning Systems Co., Ltd**
No.218, Qianwangang Road
Economic and Technological Development Zone
266555 Qingdao
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Heat pumps**

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64711220346801

Date, 2022-12-07

(Mike Zhuo)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU Declaration of conformity the required CE marking can be affixed on the product. That Declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. E8A 086688 0317 Rev. 00

Model(s): Indoor unit / outdoor unit
 AHS-044HCDSAA-23/AHW-044HCDS1,
 AHS-060HCDSAA-23/AHW-060HCDS1,
 AHS-080HCDSAA-23/AHW-080HCDS1.

Description of Object: Rated Voltage/ Frequency: 220-240V~, 50Hz
 Rated Power: See model list
 Protection class: I

Model	Rated power(kW)	Rated current(A)
AHS-044HCDSAA-23	6,8	29,56
AHS-060HCDSAA-23		
AHS-080HCDSAA-23		
AHW-044HCDS1	2,23	9,80
AHW-060HCDS1	2,73	12,00
AHW-080HCDS1	3,75	16,80

Tested according to: EN IEC 55014-1:2021
 EN IEC 55014-2:2021
 EN IEC 61000-3-2:2019/A1:2021
 EN 61000-3-3:2013/A2:2021