



Product Service

# Attestation of Conformity

No. N8A 086688 0332 Rev. 00

**Holder of Attestation:** **Qingdao Hisense Hitachi Air-conditioning Systems Co., Ltd**

No.218, Qianwangang Road  
Economic and Technological Development Zone  
266555 Qingdao  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Heat pumps  
(Heat pump)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64111230040601

**Date,** 2023-04-13

( Gary Sun )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

# Attestation of Conformity

No. N8A 086688 0332 Rev. 00

<b>Model(s):</b>	<b>Indoor unit/outdoor unit</b> <b>AHM-100HCDSAA/AHW-100HCDS1,</b> <b>AHM-120HCDSAA/AHW-120HCDS1,</b> <b>AHM-140HCDSAA/AHW-140HCDS1,</b> <b>AHM-160HCDSAA/AHW-160HCDS1</b>		
<b>Brand:</b>	<b>Hisense</b>		
<b>Parameters:</b>	Rated Voltage:	220-240V~	
	Rated Frequency:	50Hz	
	Rated Power:	Rated Power Input	Electric heater of indoor unit
	AHM-100HCDSAA	0,22kW	6kW
	AHM-120HCDSAA	0,22kW	6kW
	AHM-140HCDSAA	0,22kW	6kW
	AHM-160HCDSAA	0,22kW	6kW
	AHW-100HCDS1	4,48kW	/
	AHW-120HCDS1	5,55kW	/
	AHW-140HCDS1	6,61kW	/
	AHW-160HCDS1	8,20kW	/
	Rated Current:		
	AHM-100HCDSAA	1,91A	
	AHM-120HCDSAA	1,91A	
	AHM-140HCDSAA	1,91A	
	AHM-160HCDSAA	1,91A	
	AHW-100HCDS1	21,9A	
	AHW-120HCDS1	27,1A	
	AHW-140HCDS1	29,5A	
	AHW-160HCDS1	32,0A	
	Protection Class:	Class I	
	Degree of Protection:	IPX4 for outdoor unit, IPX1 for indoor unit	
	Refrigerant:	R32	
<b>Tested according to:</b>	EN 60335-1:2012/A15:2021 EN 60335-2-40:2003/A13:2012 EN 62233:2008		

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

