

ATTESTATION

## of conformity with European Directives

<b>BV LCIE CHINA Number</b>	N°2166AS09BXH42355-N3, 2166AF09BXH42355-N3		
Product	Heat Pump		
	1) AHW-080HCDS1+AHM-080HCDSAA		
Reference	2) AHW-060HCDS1+AHM-060HCDSAA		
	3) AHW-044HCDS1+AHM-044HCDSAA		
Issued to	Qingdao Hisense Hitachi Air-conditioning Systems Co., Ltd.		
Address	No. 218, Qianwangang Road, Economic and Technological Development Zone,		
	Qingdao, China.		
Manufacturer	Qingdao Hisense Hitachi Air-conditioning Systems Co., Ltd.		
Technical characteristics	220-240V~, 50Hz; Class I, IPX4 for outdoor units, IPX1 for indoor units		
	For outdoor unit AHW-080HCDS1: 3750W, 16,8A, R32/1,05kg;		
	For outdoor unit AHW-060HCDS1: 2730W, 12,0A, R32/0,98kg;		
	For outdoor unit AHW-044HCDS1: 2230W, 9,8A, R32/0,98kg;		
	For indoor unit AHM-080HCDSAA & AHM-060HCDSAA & AHM-		
	044HCDSAA: 3100W, 15,07A.		

The submitted sample of the above equipment has been tested for CC marking according to following European

## Directive and following standards:

Low-Voltage Directive 2014/35/EU

Standards	Report number	Report date
<ul> <li>EN 60335-2-40:2003 +A11:2004 +A12:2005</li> <li>+A1:2006 +A2:2009 + A13:2012</li> <li>EN 60335-1:2012 +A11:2014 +A13:2017</li> <li>+A1:2019 +A14:2019 +A2:2019+A15:2021</li> <li>EN 62233:2008</li> </ul>	BXH-ESH-P21091133 BXH-ESH-P21091133-A1 BXH-ESH-P21091133-A2 BXH-ESH-P21091133-A3	2021-09-30 2022-03-11 2022-12-07 2023-04-23

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the

essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

The CE marking may be affixed if all relevant and effective European Directives with CE are applicable

Shanghai (P.R. China), April 23th, 2023



oger LUO Expert

This document shall not be reproduced, except in full, without the written approval of BVLCIE China. Information given in this document, are related to the tested specimen of the described electrical sample. Page 1 of 1

Version: 8.0 / Nov.24, 2022