

This information was generated by the HP KEYMARK database on 13 Feb 2023

[Login](#)

Summary of	Hi -Therma Integra 4 6kW	Reg. No.	011-1W0579
Certificate Holder			
Name	Qingdao Hisense Hitachi Air-conditioning Systems Co.,Ltd.		
Address	Qianwangang Road	Zip	266555
City	Qingdao, Shandong	Country	China
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Hi -Therma Integra 4 6kW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	0.98 kg		
Certification Date	10.02.2023		
Testing basis	HP KEYMARK certification scheme rules rev. 11		

## Model: AHW-044HCDS1/AHS-044HCDSAA-23

Configure model	
Model name	AHW-044HCDS1/AHS-044HCDSAA-23
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.45 kW	4.45 kW
El input	0.84 kW	1.46 kW
COP	5.21	3.05

EN 14511-3 at 15 °C / 60 °C (Annex A Part D)		
	Low temperature	Medium temperature
Heat output	4.45 kW	4.45 kW
El input	0.84 kW	1.46 kW
COP	5.21	3.05

This information was generated by the HP KEYMARK database on 13 Feb 2023

<b>EN 14511-4</b>	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	201 %	130 %
Prated	4.53 kW	3.84 kW
SCOP	5.10	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.01 kW	3.40 kW
COP Tj = -7°C	3.35	1.98

This information was generated by the HP KEYMARK database on 13 Feb 2023

Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	2.43 kW	2.12 kW
COP Tj = +2°C	5.00	3.37
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.71 kW	1.41 kW
COP Tj = +7°C	6.52	4.14
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.22 kW	2.10 kW
COP Tj = 12°C	11.22	8.16
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	4.01 kW	3.40 kW
COP Tj = Tbiv	3.35	1.98
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.38 kW	3.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	9 W	9 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.15 kW	0.15 kW

This information was generated by the HP KEYMARK database on 13 Feb 2023

Annual energy consumption $Q_{he}$	1835 kWh	2381 kWh
------------------------------------	----------	----------

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	135 %
COP	3.32
Heating up time	1:58 h:min
Standby power input	26.0 W
Reference hot water temperature	46.0 °C
Mixed water at 40°C	235 l

## Model: AHW-060HCDS1/AHS-060HCDSAA-23

Configure model	
Model name	AHW-060HCDS1/AHS-060HCDSAA-23
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.99 kW	6.11 kW
El input	1.13 kW	1.96 kW
COP	5.26	3.11

EN 14511-3 at 15 °C / 60 °C (Annex A Part D)		
	Low temperature	Medium temperature
Heat output	5.99 kW	6.11 kW
El input	1.13 kW	1.96 kW
COP	5.26	3.11

This information was generated by the HP KEYMARK database on 13 Feb 2023

<b>EN 14511-4</b>	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	198 %	133 %
Prated	6.40 kW	5.31 kW
SCOP	5.03	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.66 kW	4.70 kW
COP Tj = -7°C	3.21	2.01

This information was generated by the HP KEYMARK database on 13 Feb 2023

Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.35 kW	3.05 kW
COP Tj = +2°C	4.88	3.37
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.05 kW	1.99 kW
COP Tj = +7°C	6.72	4.56
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.22 kW	2.05 kW
COP Tj = 12°C	11.22	7.43
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.66 kW	4.70 kW
COP Tj = Tbiv	3.21	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.29 kW	4.56 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.69	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	11 W	11 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.10 kW	0.80 kW



This information was generated by the HP KEYMARK database on 13 Feb 2023

Annual energy consumption $Q_{he}$	2629 kWh	3221 kWh
------------------------------------	----------	----------

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	XL
Efficiency $\eta_{DHW}$	136 %
COP	3.32
Heating up time	1:58 h:min
Standby power input	26.0 W
Reference hot water temperature	46.0 °C
Mixed water at 40°C	235 l