

$$\operatorname{\textit{Page}}\ 1$$ of 5 This information was generated by the HP KEYMARK database on 13 Feb 2023

<u>Login</u>

Summary of	Hi -Therma Integra 8kW	Reg. No.	011-1W0580	
Certificate Holder				
Name	Qingdao Hisense Hitachi Air-con	Qingdao Hisense Hitachi Air-conditioning Systems Co.,Ltd.		
Address	Qianwangang Road	Zip	266555	
City	Qingdao, Shandong	Country	China	
Certification Body	DIN CERTCO Gesellschaft für Ko	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Hi -Therma Integra 8kW	Hi -Therma Integra 8kW		
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water		
Refrigerant	R32	R32		
Mass of Refrigerant	1.05 kg	1.05 kg		
Certification Date	10.02.2023	10.02.2023		
Testing basis	HP KEYMARK certification scheme rules rev. 11			



Model: AHW-080HCDS1/AHS-080HCDSAA-23

Configure model		
Model name	AHW-080HCDS1/AHS-080HCDSAA-23	
Application	Heating + DHW + low temp	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

COP

5.07

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	8.02 kW	8.02 kW	
El input	1.58 kW	2.78 kW	

2.88

EN 14511-3 at 15 °C / 60 °C (Annex A Part D)		
	Low temperature	Medium temperature
Heat output	8.02 kW	8.02 kW
El input	1.58 kW	2.78 kW
СОР	5.07	2.88



EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	42 dB(A)	42 dB(A)	
Sound power level outdoor	64 dB(A)	64 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{S}	198 %	135 %
Prated	6.55 kW	6.25 kW
SCOP	5.03	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.79 kW	5.53 kW
COP Tj = -7 °C	3.10	1.96

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





	· · · · · · · · · · · · · · · · · · ·	
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.59 kW	3.26 kW
COP Tj = +2°C	4.87	3.42
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.48 kW	2.19 kW
$COP Tj = +7^{\circ}C$	6.74	4.56
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.06 kW	2.18 kW
COP Tj = 12°C	10.86	7.86
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.79 kW	5.53 kW
COP Tj = Tbiv	3.10	1.96
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.23 kW	5.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.69	1.54
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	10 W	10 W
РТО	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.30 kW	0.50 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Annual energy consumption Qhe	2690 kWh	3754 kWh
-------------------------------	----------	----------

Domestic Hot Water (DHW)

Average Climate

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	135 %	
СОР	3.30	
Heating up time	2:4 h:min	
Standby power input	28.0 W	
Reference hot water temperature	46.0 °C	
Mixed water at 40°C	230	