

Page 1 of 4 This information was generated by the HP KEYMARK database on 23 Jun 2022

<u>Login</u>	5	2	,
Summary of	Hi-Therma Monobloc 8kW	Reg. No.	041-K021-04
Certificate Holder		I	
Name	Qingdao Hisense Hitachi Air-conditioning Systems Co.,Ltd.		
Address	Qianwangang Road	Zip	266555
City	Qingdao, Shandong	Country	China
Certification Body	BRE Global Limited		
Subtype title	Hi-Therma Monobloc 8kW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.21 kg		
Certification Date	01.03.2022		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09		

Disclaimer: this document is a summary of the certified performance. The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.



Model: AHZ-080HCDS1

Configure model			
Model name	AHZ-080HCDS1		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	8.00 kW	8.00 kW	
El input	1.63 kW	2.86 kW	
СОР	4.90	2.80	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 3 of 4 This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	64 dB(A)	64 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η _s	197 %	137 %	
Prated	6.52 kW	6.07 kW	
SCOP	5.00	3.50	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	5.74 kW	5.34 kW	
COP Tj = -7°C	3.09	2.18	
Cdh Tj = -7 °C	0.900	0.900	
Pdh Tj = +2°C	3.47 kW	3.11 kW	
COP Tj = +2°C	4.76	3.41	
Cdh Tj = +2 °C	0.900	0.900	
Pdh Tj = +7°C	2.44 kW	2.09 kW	
COP Tj = +7°C	6.65	4.36	
Cdh Tj = +7 °C	0.900	0.900	
Pdh Tj = 12°C	1.48 kW	1.23 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com

Disclaimer: this document is a summary of the certified performance. The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.



Page 4 of 4

This information was generated by the HP KEYMARK database on 23 Jun 2022

		RK database on 23 jun 202
COP Tj = 12°C	9.58	6.52
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.74 kW	5.34 kW
COP Tj = Tbiv	3.09	2.18
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.14 kW	5.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.84	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	10 W	10 W
РТО	11 W	11 W
PSB	10 W	10 W
РСК	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.37 kW	0.25 kW
Annual energy consumption Qhe	2680 kWh	3574 kWh